



This is to certify that

## Protective Treatment M21

supplied by

# HEMPEL

Hempel UK Ltd, Berwyn House, The Pavillions, Llantarnam Park, Cwmbran,  
Torfaen, NP44 3FD

has been independently tested by

## SOCOTEC

Derwent House, Bretby Business Park, Ashby Road,  
Burton on Trent DE15 0YZ

and found to satisfy the requirements of

## Network Rail Specification NR/L3/CIV/039

7.1.2 Hempadur 1555E

25µm mdft

7.2.3 Hempadur Multi Strength GF 35870

400µm mdft

7.3.4 Hempaxane Light 55030 – Polysiloxane Finish

50µm mdft

Certificate No: **M21 - 035**

Minimum Expected Service Life: **25 years**

Formulations Review Date: **30<sup>th</sup> July 2025**

Authorised by:

**Ryan Emery**  
Operations Manager, Coatings

Date: **30<sup>th</sup> July 2020**