

This is to certify that

## Protective Treatment XN90/N4

supplied by



Jotun Paints (Europe) Ltd, Stather Road, Flixborough,  
Scunthorpe, North Lincolnshire, DN15 8RR

has been independently tested by

### *Scientifics Ltd*

ESG Derwent House, Bretby Business Park, Ashby Road,  
Burton on Trent, DE15 0YZ


and found to satisfy the requirements of

## Network Rail Line Specification NR/L3/CIV/039

<b>Blast Cleaned Steel to Surface Standard Sa2½ (BS EN ISO 8501-1)</b>	
<b>Item 7.1.2</b>	<b>Penguard Express ZP (min dft 125µm)</b>
<b>Item 7.2.2</b>	<b>Penguard Express MIO (min dft 125µm)</b>
<b>Item 7.3.1</b>	<b>Hardtop Flexi (min dft 50µm)</b>

Certificate No: XN90 – 084  
Minimum Expected Service Life: 25 years  
Formulations Review Date: 26<sup>th</sup> August 2021

Authorised by:



Ryan Emery  
Team Leader, Coatings

Date: 26th August 2016