

This is to certify that

Protective Treatment XN90/N2

Epoxy Glass Flake System for New Steelwork
(alternative to protective treatment N2)

supplied by



Jotun Paints (Europe) Ltd, Stather Road, Flixborough,
Scunthorpe, North Lincolnshire, DN15 8RR

has been independently tested by

Scientifics Ltd

ESG Derwent House, Bretby Business Park, Ashby Road,
Burton on Trent, DE15 0YZ

and found to satisfy the requirements of


Network Rail Line Specification NR/L3/CIV/039

Blast Clean to Surface Standard Sa.2½ (BS7079: Part A1)

Item 7.2.3	Jotamastic 87 GF (min dft 250µm)
Item 7.2.3	Jotamastic 87 GF (stripe coat, min dft 125µm)
Item 7.2.3	Jotamastic 87 GF (min dft 250µm)
Item 7.3.1.	Hardtop XP (min dft 80µm)

Certificate No: XN90/N2 - 056
Minimum Expected Service Life: 25 years
Formulations Review Date: 22nd January 2020

Authorised by:


Sean Carney
Team Leader, Coatings

Date: 7th March 2016