

This is to certify that

Protective Treatment XM92/M20

supplied by



Jotun Paints (Europe) Ltd, Stather Road, Flixborough,
Scunthorpe, North Lincolnshire, DN15 8RR

has been independently tested by

Scientifics Ltd

ESG Derwent House, Bretby Business Park, Ashby Road,
Burton on Trent, DE15 0YZ


and found to satisfy the requirements of

Network Rail Line Specification NR/L3/CIV/039

Blast Cleaned Steel to Surface Standard Sa2½ (BS EN ISO 8501-1)	
Item 7.1.2	Penguard Express ZP (min dft 125µm)
Item 7.2.2	Penguard Express MIO (min dft 125µm)
Item 7.3.1	Hardtop Flexi (min dft 50µm)

Certificate No: **XM92 – 162**
Minimum Expected Service Life: **25 years**
Formulations Review Date: **26th August 2021**

Authorised by:


Ryan Emery
Team Leader, Coatings

Date: **26th August 2016**