



This is to certify that

## Protective Treatment M20

supplied by

# HEMPEL

Hempel UK Ltd, Berwyn House, The Pavillions, Llantarnam Park, Cwmbran,  
Torfaen, NP44 3FD

has been independently tested by

## SOCOTEC

Derwent House, Bretby Business Park, Ashby Road,  
Burton on Trent DE15 0YZ

and found to satisfy the requirements of

## Network Rail Specification NR/L3/CIV/039

7.1.2 Hempadur 1555E	50µm mdft
7.2.2 Hempadur Mastic 45880	125µm mdft
7.2.2 Hempadur Mastic 45880	125µm mdft
7.3.1 Hempthane 55610 HS (Semi Gloss)	50µm mdft
<u>or</u>	
7.3.1 Hempthane 55810 HS (Gloss)	50µm mdft

Certificate No: **M20 - 181**  
Minimum Expected Service Life: **25 years**  
Formulations Review Date: **30<sup>th</sup> July 2025**

Authorised by:

**Ryan Emery**  
Operations Manager, Coatings

Date: **30<sup>th</sup> July 2020**