

This is to certify that

## **Protective Treatment XM92/M21**

supplied by



Jotun Paints (Europe) Ltd, Stather Road, Flixborough, Scunthorpe, North  
Lincolnshire, DN15 8RR

has been independently tested by

### **SOCOTEC**

**Derwent House, Bretby Business Park, Ashby Road,  
Burton on Trent DE15 0YZ**

and found to satisfy the requirements of


## **Network Rail Specification NR/L3/CIV/039**

**Blast Cleaned Steel to Surface Standard Sa2½ (BS EN ISO 8501-1) or, spot wet  
blast cleaned & allowed to ginger to light flash rusting as defined in SSPC-VIS  
4 (1) NACE No.7, or hand tool prepared to surface standard St3 (BS EN ISO  
8501-1).**

<b>Item 7.1.7</b>	<b>Jotamastic 90 Colour</b>	<b>250µm mdft</b>
<b>Item 7.3.4</b>	<b>Hardtop Optima Finish</b>	<b>50µm mdft</b>
<b>or</b>	<b>Hardtop CA Isocyanate Free Finish</b>	<b>50µm mdft</b>

Certificate No: **XM92/M21 – 217**

Authorised by:



Minimum Expected Service Life: **25 years (Sa2 ½)**  
**15 Years (St3)**

Formulations Review Date: **26<sup>th</sup> March 2025**

**Ryan Emery**  
**Operations Manager, Coatings**  
Date: **26<sup>th</sup> March 2020**