



This is to certify that

Protective Treatment XM92/M24

supplied by



has been independently tested by

Jotun Paints (Europe) Ltd, Stather Road, Flixborough,
Scunthorpe, North Lincolnshire, DN15 8RR

SOCOTEC

Derwent House, Bretby Business Park, Ashby Road,
Burton on Trent DE15 0YZ

and found to satisfy the requirements of

Network Rail Specification NR/L3/CIV/039

Previously coated Steel Spot Blast Cleaned to Surface Standard Sa2½ (BS EN ISO 8501-1: 2007) or Hand Tool Prepared to Surface Standard St3 (BS EN ISO 8501-1: 2007)

7.1.5 Jotamastic 90 Aluminium

75µm mdft

7.1.7 Jotamastic 90 Colour

125µm mdft

7.3.4 Hardtop Optima Finish

50µm mdft

Or Hardtop XP

50µm mdft

Or Hardtop CA Isocyanate free Finish

50µm mdft

Certificate No: **XM92/M24 – 170**
Minimum Expected Service Life: **25 years**

Authorised by:

Formulations Review Date: **18th September 2027**

A handwritten signature in black ink, appearing to read 'S. Bate'.

Scott Bate
Section Manager, Coatings

Date: **18th September 2022**