



We protect and  
beautify the world™

Dear Valued Customer,

As per your request, below is the certificate based on third party laboratory results for the system(s) of interest.

For additional information, please contact your local PPG representative.

**Limitation of Liability** - No legal consequences can be derived from the contents of this report neither is sender committed to these. The content of this report is exclusively intended for addressee(s) and information purposes. Should you receive this report, you are hereby notified that any disclosure, reproduction, distribution or use of this report is strictly prohibited. Sender accepts no liability for any damage resulting from the use and/or acceptance of the content of this report.

No part of this publication may be reproduced without the explicit, prior permission in writing from PPG or its beneficiaries or successors in title

**PPG CONFIDENTIAL INFORMATION**



COT bv  
Independent advice,  
research and  
management for  
construction and  
industry

## CERTIFICATE

The Centrum voor  
Onderzoek &  
Technisch Advies  
in Haarlem,  
The Netherlands,  
hereby declares that:

The coating system:  
SigmaFast 278, 75  $\mu\text{m}$   
SigmaFast 278, 75  $\mu\text{m}$   
SigmaDur 520, 50  $\mu\text{m}$



### Consultancy Laboratory

Jan Tademaweg 40  
2031 CV Haarlem  
P.O. Box 2113  
2002 CC Haarlem  
The Netherlands  
T +31 23-5319544  
F +31 23-5277229  
E [info@cot-nl.com](mailto:info@cot-nl.com)  
I [www.cot-nl.com](http://www.cot-nl.com)

from manufacturer/supplier: PPG  
One PPG Place  
38N Pittsburgh  
PA 15272  
U.S.A.

meets the requirements of: ISO 12944-6:2018

Corrosion category: C3

Durability range: High

This certificate is based  
upon the results of report: LAB18-0269-REP Rev. 2

Date: July 25<sup>th</sup>, 2018

For COT For PPG