

REGULATION 31(4)(A) OF THE WATER SUPPLY (WATER QUALITY) REGULATIONS 2016 SI No
614
& THE WATER SUPPLY (WATER QUALITY) REGULATIONS 2010 SI No 994 (W.99)

APPROVAL CONFIRMATION

Product name/designation	SikaGard 62
Approval Category(ies)	C.3.1 Coatings based on epoxy resins
Approval Holder (Name & Address)	Sika Ltd Welchmead Welwyn Garden City AL7 1BQ
Instructions for Use	IFU, Sikagard62.IFU.V2.2012
DWI Ref Number	DWI 56.4.197

The Secretary of State for Environment, Food and Rural Affairs in respect of relevant water¹ suppliers whose area of supply is wholly or mainly in England, and the Welsh Ministers in respect of relevant water suppliers whose area of supply is wholly or mainly in Wales, in exercise of their powers under Regulation 31(4)(a) of the Water Supply (Water Quality) Regulations 2016 and Regulation 31(4)(a) of the Water Supply (Water Quality) Regulations 2010 (as amended) (Wales) respectively hereby approve the introduction or application of the product detailed above, in accordance with the following Conditions:

CONDITIONS OF APPROVAL

The above named product is approved for application in England and Wales² by a relevant water supplier for public water supply purposes subject to the following conditions:

1. Relevant water suppliers shall be provided with a copy of the Instructions for Use (IFU) detailed above and use of the product must be in accordance with the IFU.
2. The Drinking Water Inspectorate (DWI) must be notified, in advance and in writing, by the approval holder detailed above, in respect of any change in –
 - a) The Instructions for Use
 - b) The formulation of the approved product, including change in source or identity of raw materials
 - c) The manufacturing process, including location of manufacture
 - d) The designation of the approved product
 - e) The name, address or ownership of the organisation holding the approvalFailure to notify such changes will result in approval being withdrawn.
3. The approval holder shall ensure that the product is tested for conformity with its formulation, and the source or identity of its raw materials, at such intervals and by such persons, as may be determined by the DWI and the results of such testing shall be sent to DWI.
4. The use of the Drinking Water Inspectorate, DEFRA or Welsh Government logos, in respect of any approved product (including on the product or in editorial or advertising/trade copy) is not permitted.
5. The following product specific condition(s) apply – *The product must be cured in accordance with the cure curves provided in the Instructions for Use. The required cure time can be calculated by the user from the minimum daily temperature at the site of application. If the temperature cannot be measured and recorded then a minimum cure period of 21 days must be used.*

Signed by authority of the Secretary of State
and the Welsh Ministers



Marcus Rink
Chief Inspector of Drinking Water
England and Wales

Date of Issue: 08 May 2017

Date of Expiry: 03 September 2022

¹ Relevant water suppliers shall include water undertakers, water supply licensees and inset appointees.

² Separate approval arrangements apply in Scotland and Northern Ireland