



This is to certify that

Protective Treatment M24

supplied by



SHERWIN-WILLIAMS.

Tower Works, Kestor Street, Bolton, BL2 2AL

has been independently tested by

SOCOTEC

Derwent House, Brelby Business Park, Ashby Road,
Burton on Trent DE15 0XD

and found to satisfy the requirements of

Network Rail Specification NR/L3/CIV/039

| | | |
|----------------|----------------|-------------|
| Item No. 7.1.5 | Macropoxy M902 | 100µm mdfit |
| Item No. 7.1.7 | Macropoxy M905 | 100µm mdfit |
| Item No. 7.3.1 | Acrolon C137V2 | 50µm mdfit |

Certificate No: M24 - 014
Minimum Expected Service Life:
25 years – Blast cleaned steelwork
15 years – St3 prepared steelwork or
aged existing coatings
Formulations Review Date: 23rd May 2023

Authorised by:

Ryan Emery
Operations Manager, Coatings

Date: 23rd May 2018